

NOTES:

- 1. STREET LIGHTS REQUIRED AT FIRE HYDRANTS AND INTERSECTIONS.
- 2. FIRE HYDRANT SPACING PER CURRENT INTERNATIONAL FIRE CODE.
- MINIMUM VERTICAL CLEARANCE WHERE CLOSER THAN 10' OR AT SEWER/WATER CROSSING.
- 4. SIGN LOCATIONS PER CURRENT WUTCD CODE.
- SEWER MANHOLES TO BE LOCATED IN CENTER OF ROAD.
- HYDRANT LOCATION DETERMINED BY SPEED AND ROAD GRADE.
 MAY BE REQUIRED TO BE ON BACK OF WALK.
- GUARDRAIL REQUIRED ON ALL FILL SLOPES STEEPER THAN 3:1
 WHERE THE VERTICAL DROP OF THE SLOPE IS GREATER THAN 8'.

TYPICAL COVER OVER UTILITIES

- SEWER, 8'
- WATER PER LOCAL WATER AGENCY
- STORM DRAIN, 30" MINIMUM
- GAS, 30"
- POWER, 40"
- TELEPHONE, 24"
- TELEVISION, 24"

TYPICAL UTILITY SEPARATION

- SEWER / WATER 10' HORIZONTAL, 2' VERTICAL
- GAS MINIMUM 3' HORIZONTAL
- POWER MINIMUM 12" HORIZONTAL
- TELEPHONE MINIMUM 12" HORIZONTAL
- TELEVISION MINIMUM 12" HORIZONTAL